

Test Certificate

D.N. BICKERTON
ELECTRICAL LTD

Tests Conducted By: D N Bickerton Electrical Ltd, P O Box 194, Drury, Auckland, New Zealand

On Behalf Of: Test Company Auckland

Site: Greenmount Driv

Asset: 168

Description: LEAD

Testcode: K1D7000011 S111111111

Make:

Model:

Serial No:

Test	Result	Unit	Status
Visual (Plugs)			Pass
Visual (Flexible Cord)			Pass
Visual (Cover / Guards)			Pass
Earth Current	25	A	Information
Earth	0.04	Ohm	Pass
Insulation	>99.99	MOhm	Pass
Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 19/07/2007

Test Instrument: Seaward Supernova XE W03-0055

Tested By: BEN

Signed By: